



## **Temple Volunteer Fire Department**

**423 NH Route 45**

**Po Box 80**

**Temple, NH 03084**

**603-801-8607**

**Chief: George Clark    Deputy Chief: Ken Caisse**

To ZBA Chair Mr. Kieley,

I am writing this letter regarding Steppingstone farm and event center. Ms. Martin has been working very hard to bring the barn up to code with NFPA 101 2015 edition which is the NH adopted Life safety code. Ms. Martin has leveled off the entrance grade, fixed the egress stairs, had emergency lighting put in, has purchased the spray for the interior walls and we met today with a company about installing a commercial grade smoke detector system. Once the spray is on and smoke detector system installed she will be up to full compliance.

As for the fire watch, Ms. Martin has gotten to the point where I have agreed to provide a fire watch and have the blessing of the selectboard to do so. There will be a fire watch at all events held here until the alarm system is put in.

Any questions feel free to contact me.

Sincerely,

A handwritten signature in black ink, appearing to read "George Clark".

George Clark  
Fire Chief