




# MERIDIAN LAND SERVICES, INC.

CIVIL ENGINEERING | LAND SURVEYING | PERMITTING | SOIL & WETLAND MAPPING | SEPTIC DESIGN | ENVIRONMENTAL

Office: 31 Old Nashua Road, Suite 2, Amherst, NH 03031  
Mailing: PO Box 118, Milford, NH 03055  
Phone: 603-673-1441 \* Fax 603-673-1584  
www.MeridianLandServices.com

November 2, 2023

Name: Allan Pickman & Robin Downes  
Town: Temple, NH  
Job #: 12275.00  
Date Observed: 8/31/2023



### Test Pit 1

0-9" 10YR 3/3 Dark Brown, Fine Sandy Loam  
Granular, Very Friable  
9"-18" 7.5YR 4/6 Strong Brown, Stony Fine Sandy Loam  
Subangular Blocky, Very Friable  
18"-20" 2.5Y 6/8 Olive Yellow, Stony Sandy Loam  
Massive, Friable

WATER: None S.H.W.: None ROOTS: 16"  
LEDGE: 20" HARDPAN: None  
PERCOLATION RATE: 10 MIN./IN. AT 16" DEPTH  
DATE: 8/31/23  
INSPECTED BY: JCB WITNESSED BY: PC

### Test Pit 2

0-11" 10YR 3/3 Dark Brown, Fine Sandy Loam  
Granular, Very Friable  
11"-21" 7.5YR 4/6 Strong Brown, Fine Sandy Loam  
Subangular Blocky, Very Friable  
21"-44" 7.5YR 3/3 Dark Brown, Stony Loamy Sand  
Granular, Friable  
44"-52" 2.5Y 6/1 Gray, Stony Gravelly Loamy Sand  
Massive, Very Friable

WATER: None S.H.W.: 38" ROOTS: 10"  
LEDGE: >52" HARDPAN: None  
PERCOLATION RATE: 8 MIN./IN. AT 30" DEPTH  
DATE: 8/31/23  
INSPECTED BY: JCB WITNESSED BY: PC

### Test Pit 3

0-6" 10YR 3/3 Dark Brown, Fine Sandy Loam  
Granular, Very Friable  
6"-13" 10YR 4/6 Dark Yellowish Brown, Fine Sandy  
Loam, Subangular Blocky, Very  
Friable  
13"-30" 2.5Y 6/1 Gray, Sandy Loam, Massive, Friable

WATER: None S.H.W.: 20" ROOTS: 6"  
LEDGE: 30" HARDPAN: None  
PERCOLATION RATE: 8 MIN./IN. AT 16" DEPTH  
DATE: 8/31/23  
INSPECTED BY: JCB WITNESSED BY: PC

### Test Pit 4

0-8" 10YR 3/3 Dark Brown, Fine Sandy Loam  
Granular, Friable  
8"-24" 2.5Y 5/6 Light Olive Brown, Fine Sandy Loam  
Subangular Blocky, Very Friable  
24"-29" 2.5Y 5/6 Light Olive Brown, Sandy Loam  
Massive, Friable

WATER: None S.H.W.: 19" ROOTS: 16"  
LEDGE: 29" HARDPAN: None  
PERCOLATION RATE: 10 MIN./IN. AT 18" DEPTH  
DATE: 8/31/23  
INSPECTED BY: JCB WITNESSED BY: PC



# MERIDIAN LAND SERVICES, INC.

CIVIL ENGINEERING | LAND SURVEYING | PERMITTING | SOIL & WETLAND MAPPING | SEPTIC DESIGN | ENVIRONMENTAL

Office: 31 Old Nashua Road, Suite 2, Amherst, NH 03031

Mailing: PO Box 118, Milford, NH 03055

Phone: 603-673-1441 \* Fax 603-673-1584

www.MeridianLandServices.com

## Test Pit 5

0-11" 10YR 3/3 Dark Brown, Fine Sandy Loam  
Granular, Very Friable  
11"-30" 10YR 3/6 Dark Yellowish Brown, Stony Fine  
Sandy Loam, Subangular Blocky  
Very Friable  
30"-50" 2.5Y 5/3 Light Olive Brown, Stony Loamy Sand  
Massive, Friable

WATER: **None** S.H.W.: 30" ROOTS: 24"  
LEDGE: >50" HARDPAN: **None**  
PERCOLATION RATE: 10 MIN./IN. AT 29" DEPTH  
DATE: 8/31/23  
INSPECTED BY: JCB WITNESSED BY:

## Test Pit 6

0-17" 10YR 3/3 Dark Brown, Fine Sandy Loam  
Granular, Very Friable  
17"-49" 2.5Y 4/2 Dark Grayish Brown, Stony Fine  
Sandy Loam, Massive, Friable

WATER: 38" S.H.W.: 17" ROOTS: 15"  
LEDGE: >49" HARDPAN: **None**  
PERCOLATION RATE: 12 MIN./IN. AT 15" DEPTH  
DATE: 8/31/23  
INSPECTED BY: JCB WITNESSED BY: PC

## Test Pit 7

0-8" 10YR 3/2 Very Dark Grayish Brown, Loam  
8"-17" 2.5Y 4/3 Grayish Brown, Fine Sandy Loam  
Granular, Very Friable  
17"-20" 10YR 4/3 Brown, Sand, Single Grain, Loose  
20"-48" 2.5Y 4/3 Olive Brown, Stony Sandy Loam  
Massive, Friable

WATER: 36" S.H.W.: 15" ROOTS: 20"  
LEDGE: >48" HARDPAN: **None**  
PERCOLATION RATE: 10 MIN./IN. AT 14" DEPTH  
DATE: 8/31/23  
INSPECTED BY: JCB WITNESSED BY: PC